

Paper 4 – Energy Auditor – Set A Solutions

Regn No: _____

Name: _____

(To be written by the candidate)

9TH NATIONAL CERTIFICATION EXAMINATION– December, 2009 FOR ENERGY AUDITORS

PAPER – 4: Energy Performance Assessment For Equipment and Utility Systems

Date: 20.12.2009 Timings: 1400-1600 HRS Duration: 2 HRS Max. Marks: 100

General instructions:

- Please check that this question paper contains **8** printed pages
- Please check that this question paper contains **16** questions
- The question paper is divided into three sections
- All questions in all three sections are compulsory
- All parts of a question should be answered at one place

Section - I: SHORT DESCRIPTIVE QUESTIONS

Marks: 10 x 1 = 10

- (i) Answer all **Ten** questions
- (ii) Each question carries **One** mark

S-1	A cogeneration plant with a back pressure turbine has a constant steam demand and fluctuating power demand. What is the common option to meet the fluctuating power demand? Ans Parallel operation with grid
S-2	What are the two major sources of waste heat available from a water-cooled Diesel Generator set? Ans Exhaust flue gases and jacket cooling water
S-3	For determining heat loss in flue gases due to incomplete combustion which flue gas constituent needs to be measured? Ans Carbon monoxide

Paper 4 – Energy Auditor – Set A Solutions

S-4	Which parameter needs to be measured to assess the percentage loading of a motor by slip method neglecting voltage correction? Ans Motor speed
S-5	How many volt-amperes (VA) does a 100 Watt incandescent light require? Ans 100 VA
S-6	In the indirect method of boiler efficiency evaluation, list any two additional losses computed for solid fuel fired boilers as compared to liquid and gas fired boilers? Ans. Unburnt losses in fly ash (Carbon) Unburnt losses in bottom ash (Carbon)
S-7	Why do biomass combustion projects qualify for CDM benefits even though they emit carbon dioxide? Ans: Because it absorbs the same amount of carbon in growing as it releases when consumed as fuel Biomass is carbon neutral Or
S-8	Name two most common bio fuels used for transportation Ans 1. Biodiesel 2. Ethanol
S-9	Which loss is assumed in the determination of electric motor efficiency? Ans The stray load loss is estimated and not measured for testing electric motor efficiency.
S-10	In a shell and tube heat exchanger, engaged in heat transfer between fouling fluid and clear fluid, the fouling fluid should be put on shell side or tube side? Ans Tube side

..... **End of Section - I**

Paper 4 – Energy Auditor – Set A Solutions

Section - II: LONG DESCRIPTIVE QUESTIONS

Marks: 2 x 5 = 10

- (i) Answer all **Two** questions
- (ii) Each question carries **Five** marks

L-1 The steam flow to a process plant is 5000 kg/hr. 2000 kg/hr of condensate at 173°C is returned to boiler feed water tank due to its own pressure. However there is 10% heat loss in transit to boiler feed tank. The balance is made up as feed water at 30°C. The final feed water temperature observed was 95°C. Comment on the feed water temperature. The plant personnel are sure that the temperature gauge is in order.

Ans Heat in condensate (less 10%) + Heat in make up water = Heat in feed water

$$2000 \times 173 \times 0.9 + 3000 \times 30 = 5000 \times T_f$$
$$311400 + 90000 = 5000 \times T_f$$

$$T_f = 80.28^\circ\text{C}$$

(3 Marks)

The feed water temperature cannot be more than 80.28°C. The high temperature of 95°C is mostly due to live steam leakage, as the temperature gauge is OK.

(2 Marks)

L-2 The maximum demand registered by an automobile plant is 5000 KVA and the power factor is 0.95. The plant management converts the existing electrical resistance heated furnace with an average load of 750 kW to gas heating as a cost reduction measure. What will be effect on maximum demand and power factor with this conversion?

Ans. Registered maximum demand = 5000 KVA
Electrical load (real power) = 5000 X 0.95
= 4750 KW

$$\text{KVAR}^2 = \text{KVA}^2 - \text{KW}^2$$
$$\text{KVAR}^2 = (5000)^2 - (4750)^2$$

$$\text{KVAR} = \frac{100 \sqrt{(50^2) - (47.5)^2}}{1561}$$

(3 Marks)

KVAR in the system will remain same.

Reduction in real power by conversion is 750 KW.

$$\text{Real Power} = 4750 - 750 = 4000 \text{ KW}$$

$$\text{KVA}^2 = \text{KW}^2 + \text{KVAR}^2$$
$$= (4000)^2 + (1561)^2$$
$$\text{KVA} = 4294$$

$$\text{Power factor} = 4000 / 4294 = 0.932$$

$$\text{Reduction in Electrical Demand} = 5000 - 4294$$
$$= 706 \text{ KVA}$$

Paper 4 – Energy Auditor – Set A Solutions

$$\begin{aligned}\text{Reduction in Power Factor} &= 0.95 - 0.932 \\ &= 0.018\end{aligned}$$

(2 Marks)

..... **End of Section - II**


Section - III: NUMERICAL QUESTIONS

Marks: 4 x 20 = 80

- (i) Answer all **Four** questions
- (ii) Each question carries **Twenty** marks

N -1 Given below is a set of curves for a centrifugal fan. At its Best Efficiency Point (BEP) determine to the **nearest approximation** the following:

- a) Static pressure in mmwc
- b) Flow in m³/hr
- c) Shaft power in kW
- d) Work out the static efficiency of the fan by calculation
- e) Power drawn by the motor if the motor operating efficiency is 90%



Ans

Static pressure in inches H ₂ O	36
	(2 Marks)
Static pressure in mmwc	914.4 mmwc
	(2 Marks)
Flow in CFM	2750


Paper 4 – Energy Auditor – Set A Solutions

	(2 Marks)
Flow in m ³ /hr	4672.28 m ³ /hr ie 1.3 m ³ /sec
	(2 Marks)
Shaft power in hp	29
	(2 Marks)
Shaft power in kW	21.6 kW
	(2 Marks)
Fan Efficiency	$Q \times dP / (102 \times kW)$
	$1.3 \times 914.4 / (102 \times 21.6)$
	54 %
	(5 Marks)
Motor input power at 90%	$21.6 / 0.9$
	= 24 kW
	(3 Marks)

The data is read from the graph and hence a deviation of +/- 10% in values may be given full marks.

- N-2 In a Continuous Process Industry 5 Tonne per hour hot oil on process stream has to be cooled from 230°C to 110°C by DM water at 25°C heated to 80°C on its route to boiler de-arator.
- Depict the heat exchange process on a schematic for both parallel and counter flow heat exchanger clearly indicating inlet and outlet temperature and terminal temperature difference.
 - Find out LMTD for parallel and counter flow heat exchangers and comment on the preference of the heat exchanger.
 - Find out the DM water flow rate through the heat exchanger. Assume specific heat of hot oil to be 0.5 kCal / kg°C.

Ans.



$$\text{LMTD parallel flow} = \frac{\Delta t_1 - \Delta t_2}{\ln \Delta t_1 / \Delta t_2}$$

Paper 4 – Energy Auditor – Set A Solutions

$$= \frac{205 - 30}{\ln 205 / 30} = 91.15^{\circ}\text{C}$$

(8 Marks)

$$\text{LMTD counter-flow} = \frac{\Delta t_1 - \Delta t_2}{\ln \Delta t_1 / \Delta t_2}$$

$$= \frac{150 - 85}{\ln 150 / 85} = 114.44^{\circ}\text{C}$$

(8 Marks)

Counter flow heat exchanger is preferred as the LMTD is larger and hence heat exchanger area will be less and compact.

$$\begin{aligned} M_c \times 1 \times (80 - 25) &= m_h \times C_{ph} \times (230 - 110) \\ M_c &= \frac{5000 \times 0.5 \times (230 - 110)}{55} \\ &= 5454.54 \text{ Kg / hr} \end{aligned}$$

$$\text{DM water flow rate} = 5454.54 \text{ Kg / hr}$$

(4 Marks)

- N-3 The following are the data collected for a boiler using furnace oil as the fuel. Determine the boiler efficiency based on GCV by indirect method ignoring radiation and convection losses.

Ultimate chemical analysis (% weight) : Carbon : 84, Hydrogen : 12, Nitrogen : 0.5, Oxygen : 1.5, Sulphur : 1.5, Moisture : 0.5, GCV of fuel 10,397 kCal/kg and humidity 0.015 kg moisture/kg of dry air.

Flue gas analysis: CO₂ : 12% volume, flue gas temperature : 180°C and ambient temperature : 20°C

Ans:

a) Theoretical Air = $11.43 \times 0.84 + 34.5 \times (0.12 - 0.015/8) + 4.32 \times 0.015 = \underline{13.74}$

(or)

$$\text{Theoretical Air} = 11.6 \times 0.84 + 34.8 \times (0.12 - 0.015/8) + 4.35 \times 0.015 = \underline{13.92}$$

(2 Marks)

b) Theoretical % CO₂ = Moles of C / (Moles of N₂ + Moles of C + Moles of Sulphur)
 = $100 \times (0.84/12) / (13.74 \times 0.77/28 + 0.005/28 + 0.84/12 + 0.015/32) = \underline{15.62\%}$
 (or)

Paper 4 – Energy Auditor – Set A Solutions

$$\text{Theoretical \% CO}_2 = \frac{\text{Moles of C}}{\text{Moles of N}_2 + \text{Moles of C} + \text{Moles of Sulphur}} \\ = 100 \times (0.84/12) / (13.92 \times 0.77/28 + 0.005/28 + 0.84/12 + 0.015/32) = \underline{15.44\%}$$

(2 Marks)

Depending on the variation in the above values (a and b) the subsequent calculations will also have a minor variation in the end result, which can be ignored.

$$\text{c) Excess air supplied} = 7900 \times (15.62 - 12) / (12(100 - 15.62)) = \underline{28.24\%}$$

(2 Marks)

$$\text{d) Actual mass of air supplied} = (1 + 0.2824) \times 13.74 = \underline{17.62 \text{ kg/kg of oil.}}$$

(2 Marks)

$$\text{e) Actual mass of dry flue gas} = \\ 0.84 \times 44/12 + 0.005 + 17.62 \times 0.77 + 0.015 \times 64/32 + 3(17.62 - 13.74) \times 0.23 \\ = \underline{19.3596 \text{ kg/kg oil}}$$

(2 Marks)

$$\text{f) \% loss by dry flue gas} = \underline{19.3596} \times 0.23 \times (180 - 20) / 10,397 = 0.0685 \text{ or } \underline{6.85\%}$$

(2 Marks)

$$\text{g) \% loss by formation of water from Hydrogen in the fuel} \\ 9 \times 0.12 \times (584 + 0.45(180 - 20)) / 10,397 = 0.681 \text{ or } \underline{6.81\%}$$

(2 Marks)

$$\text{h) \% loss due to moisture in fuel} = 0.005 \times (584 + 0.45(180 - 20)) / 10,397 = \underline{0.03\%}$$

(2 Marks)

$$\text{i) \% loss due to moisture in air} = 17.62 \times 0.015 \times 0.45(180 - 20) / 10,397 = \underline{0.183\%}$$

(2 Marks)

$$\text{j) Boiler efficiency} = 100 - 6.85 - 6.81 - 0.03 - 0.183 = \underline{86.127\%}$$

(2 Marks)

N-4 A process plant is installing a 5 MW gas turbine cogeneration system with 12 TPH waste heat boiler to meet the power and steam demand of the plant. The plant will operate at 90% of capacity, meeting the entire power requirement of the plant, which is presently drawn from grid supply. The co-gen plant will also meet the steam requirement of 10 TPH, which is presently generated in a gas fired boiler with 86% efficiency on N.C.V. basis. Calculate the differential cost between cogenerated power and grid power per unit and also the additional natural gas requirement per day based on the following data.

Capacity of gas turbine	=	5000 kW
Plant load factor	=	90%
Auxiliary power consumption	=	1%
Operating hrs. per annum	=	8000
Net calorific value of natural gas	=	9500 kCal / Sm ³
Cost of natural gas	=	Rs.8 / Sm ³
Steam produced by co-gen waste heat	=	10 TPH boiler
Annual expenditure towards depreciation and interest	=	Rs 500 lacs
Annual expenditure for operation &		

Paper 4 – Energy Auditor – Set A Solutions

maintenance of co-gen plant	=	Rs 200 lacs	
Heat Rate of gas turbine on NCV	=	3050 kCal / kWh	
Cost of electric power from grid supply	=	Rs. 4.5/ kWh	
Enthalpy of steam	=	665 kCal/ kg	
Feed water temperature	=	85°C	
Ans			
Power generation from cogen plant	=	5000X 0.9 X 8000 = 360 lac Kwh	
Auxiliary power	=	1%	
Net power generation	=	0.99 X 360 = 356.4 lac Kwh	
Natural gas requirement for power generation	=	360 X 3050 / 9500 = 115.57 lac Sm³	
			(4 Marks)
Cost of fuel per annum	=	115.57 X 8 = Rs.924.56 lacs	
Annual expenditure for interest, depreciation and O&M	=	500 + 200 = 700 lacs	
Total cost of generation	=	Rs.1624.56 lacs.	
Cost of cogeneration power		=1624.56 X 10⁵ / 356.4 X 10⁵	
		=Rs.4.56 / Kwh.	(4 Marks)
Gas consumption in existing gas fired boiler	=	[10000 (665 – 85) / (0.86 X 9500)]	
	=	710 Sm³/hr	
	=	17040 Sm³/day	
Cost of steam	=	710*Rs. 8/10	
	=	Rs. 568/Ton	
Annual savings by avoiding steam in the existing gas fired Boiler	=	10 X 568 X 8000	
	=	Rs. 454.4 Lacs.	
Cost of generation after giving credit for steam generation	=	1624.56 – 454.4 = Rs.1170.16 lacs	
Cost of generation after accounting for steam cost	=	1170.16 X 10⁵ / 356.4 X 10⁵	
	=	Rs. 3.28 / Kwh	(5 Marks)
Grid power cost	=	Rs. 4.5 / Kwh	
Cost advantage for cogen plant generation	=	4.5 – 3.28 = Rs.1.22 / Kwh	
Daily gas requirement for operating GT cogen plant	=	5000 X 0.9 X <u>3050</u> X 24 / 9500	
	=	34673.68 Sm³ / day	(3 Marks)
Additional gas requirement for co-gen plant	=	34673.68 – 17040 = 17633.68 Sm³/day	
			(4 Marks)

----- End of Section - III -----